



K-MARK



ACB PC 03

PRODUCT CERTIFICATE OF CONFORMITY

Certificate No : IKRAM 01416FT

Certificate Holder

**GEORGE FISCHER (M) SDN. BHD.,
No. 2, 4 & 6, Jalan Permata 3/KS 09, Taman Perindustrian Air Hitam,
41200 Klang, Selangor Darul Ehsan, Malaysia.**

Product Name

Polypropylene (PP) Fittings For Soil And Waste Discharge

Standard

ISO 7671 : 2003

Product Description

Product descriptions shall refer ANNEX

Brands



SILENTA

Manufacturer

**GEORG FISCHER HAKAN PLASTIK BORU VE PROFIL SAN. TIC. A.S.
COSB, Gaziosmanpasa Mh. 3, Cd. No: 11-13,
Cercezkoy, Tekirdag, Turkey.**

Date of original issue
08.04.2016

Date of renewal
10.05.2023

Date of amendment
23.06.2023

Expiry Date
30.06.2024



MOHAMAD AKHIR BIN ABDULLAH
Director

DATO' TS. HAJI MOHD TAUFIK BIN HARON
Chairman

This certificate remains the property of IKRAM QA SERVICES SDN.BHD. and shall be returned on request.
IKRAM QA Services Sdn. Bhd. (199901004665)
Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten, 43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254 Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



IKRAM QA Services Sdn. Bhd. (199901004665)
Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten,
43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254
Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



ANNEX - Page 1

Certificate No : IKRAM 01416FT

Certificate Holder : GEORGE FISCHER (M) SDN. BHD.,

Date of original issue
08.04.2016

Date of renewal
10.05.2023

Date of amendment
23.06.2023

Expiry Date
30.06.2024

Pipe Series	Type of Fittings	Nominal Size (DN)
S 16	Bend (15°, 45°, 67.5°, 87.5°), Single Branch, Double Branch (45°, 67.5°, 87.5°) Access Fitting, Double Socket, Plug, Repair Collar, Reducer	40, 50, 63, 75, 80, 90, 100, 110
S 20	Reducer, Single Branch	125, 160, 200

All Fittings With Integral Elastomeric Ring Seal Socket
Type of Polypropylene : Polypropylene Copolymer (PP)
Polypropylene Resin : PP Grade – Repsol PB150G2M

Note : The fittings shall be installed at ambient temperature.



IKRAM QA Services Sdn. Bhd. (199901004665)
Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten,
43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254
Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



ANNEX - Page 2

Certificate No : IKRAM 01416FT

Certificate Holder : GEORGE FISCHER (M) SDN. BHD.,

Date of original issue
08.04.2016

Date of renewal
10.05.2023

Date of amendment
23.06.2023

Expiry Date
30.06.2024

Certificate Descriptions :

1. IKRAM QA Services Sdn. Bhd. is accredited by Department of Standards Malaysia (Standards Malaysia) according to ISO/IEC 17065 : 2012 for certification of products with certificate number ACB PC 03.
2. This certificate has been approved and issued in compliance with **IKRAM QA Scheme 1**.
3. IKRAM QA Scheme 1 is product certification scheme owned by IKRAM QA which using certification scheme Type 5.
4. It is hereby certified that the product as detailed in this certificate has satisfactorily complied with the requirement of the appropriate Product Standard(s).
5. Certification mark for IKRAM QA Scheme 1 is **K-Mark**.

Certificate Information :

Product Code : H0222

Old Certificate Number : IKRAM-I237-H0222-NF1416

1. P1 – KPS 52/17 (16.03.2017) – Update product descriptions and amendment of expiry date from month of May to June on 16.03.2017.
2. P2 – KPS 109/18 (03.09.2018) – Change of certificate holder's address from original address No. 14, Jalan Anggerik Mokara 31/50, Section 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia on 17.07.2018 and correction of product descriptions.
3. P3 – KPS 71/23 (23.06.2023) – Correction of product standard.