



K-MARK

PRODUCT CERTIFICATE OF CONFORMITY

Certificate No : IKRAM 01612MP

Certificate Holder

**BELLS MARKETING SDN. BHD.,
No. 1, Jalan Perunding U1/17, Glenmarie Industrial Park,
40150 Shah Alam, Selangor Darul Ehsan, Malaysia.**

Product Name

Cast Iron Check Valves

Standard

BS EN 16767 : 2020

Product Description

Product descriptions shall refer to ANNEX

Brands



Manufacturer

**ARITA VALVE MFG. (M) SDN. BHD.,
Lot 414, Lorong Perusahaan 8C, Prai Industrial Estate,
13600 Seberang Perai, Pulau Pinang, Malaysia.**

Date of original issue

27.06.2012

Date of renewal

20.06.2023

Date of amendment

05.07.2022

Expiry Date

31.07.2024



MOHAMAD AKHIR BIN ABDULLAH
Director

DATO' TS. HAJI MOHD TAUFIK BIN HARON
Chairman

This certificate remains the property of IKRAM QA SERVICES SDN.BHD. and shall be returned on request.
IKRAM QA Services Sdn. Bhd. (199901004665)

Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten, 43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254 Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



IKRAM QA Services Sdn. Bhd. (199901004665)
Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten,
43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254
Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



ANNEX - Page 1

Certificate No : IKRAM 01612MP

Certificate Holder : BELLS MARKETING SDN. BHD.,

Date of original issue
27.06.2012

Date of renewal
20.06.2023

Date of amendment
05.07.2022

Expiry Date
31.07.2024

Type of Valve	Pressure Rating	Nominal Size (DN)	Body End
Swing Check Valve Seat Material : Metal Seated Material : Grey Cast Iron Material Grade : EN-GJL-200	PN10	100, 125, 150, 200	Flanged Type
Swing Check Valve Seat Material : Resilient Seated Material : *Spheroidal Graphite Cast Iron Material Grade : EN-GJS-500-7	PN16	50, 65, 80, 100, 125, 150, 200	Flanged Type, Wafer Type
Lift Check Valve Seat Material : Resilient Seated Material : *Spheroidal Graphite Cast Iron Material Grade : EN-GJS-500-7	PN16	250, 300, 350, 400, 450	Flanged Type

Coating: Epoxy (Cold Applied or Fusion Bonded)

*Note : Also referred to as Ductile Iron.



IKRAM QA Services Sdn. Bhd. (199901004665)
Address: Block 5, Level 1, Unipark Suria, Jalan Ikram – Uniten,
43000 Kajang, Selangor Darul Ehsan, Malaysia.
Tel: +603 8738 3212 Fax: +603 8736 7254
Email: ikramqa@ikram.com.my Website: www.ikramqa.com.my



ANNEX - Page 2

Certificate No : IKRAM 01612MP

Certificate Holder : BELLS MARKETING SDN. BHD.,

<i>Date of original issue</i>	<i>Date of renewal</i>	<i>Date of amendment</i>	<i>Expiry Date</i>
27.06.2012	20.06.2023	05.07.2022	31.07.2024

Certificate Descriptions :

1. IKRAM QA Services Sdn. Bhd. is certification body operating according to ISO/IEC 17065 : 2012.
2. This certificate has been approved and issued in compliance with **IKRAM QA Scheme 1**.
3. IKRAM QA Scheme 1 is product certification scheme owned by IKRAM QA which using certification scheme Type 5.
4. It is hereby certified that the product as detailed in this certificate has satisfactorily complied with the requirement of the appropriate Product Standard(s).
5. Certification mark for IKRAM QA Scheme 1 is **K-Mark**.

Certificate Information :

Product Code : E0508

Old Certificate Number : IKRAM-P035E1-E0508-N1612

1. P1 – KM 12/12 (14.11.2012) – Amendment of expiry date from June to July on 16.06.2014
2. P2 – KPS 90/17 (05.06.2017) – Update product descriptions and brand.
3. P3 – KPS 75/20 (27.07.2020) – Additional type and size.
4. P4 – KPS 72/22 (05.07.2022) – Update product standard.